



Haripur 412 MW Combined Cycle Power Plant

ELECTRICITY GENERATION COMPANY OF BANGLADESH LIMITED

Haripur, Bandar, Narayanganj.

FY 2021-22

FY 2022-23

Month	Plant Factor	Plant Availability	Auxiliary Consumption (Self)	% of Aux Con	Month	Plant Factor	Plant Availability	Auxiliary Consumption (Self)	% of Aux Con	Remarks
Unit	%	Afm	KWh	%	Unit	%	Afm	KWh	%	
Jul-21	87.38	100.00	11,064,550	4.37	Jul-22	84.82	100	9,167,376	3.71	
Aug-21	76.24	89.19	8,024,624	3.63	Aug-22	106.07	100	10,788,354	3.49	
Sep-21	74.16	88.07	8,224,259	3.95	Sep-22	78.56	94.55	8,330,218	3.76	
Oct-21	92.27	99.83	10,787,256	4.01	Oct-22	82.76	95.5	8,948,596	3.71	
Nov-21	95.84	100.00	10,546,476	3.90	Nov-22	64.21	100	7,130,610	3.93	
Dec-21	42.54	99.15	4,801,030	3.87	Dec-22	101.98	100	10,771,728	3.62	
Jan-22	0.00	100.00	Shutdown	Shutdown	Jan-23	92.60	98.53	10,489,736	3.88	
Feb-22	36.25	71.54	3,941,536	4.13	Feb-23	58.18	66.94	5,742,920	3.75	
Mar-22	0.00	0.00	Shutdown	Shutdown	Mar-23	99.75	99.32	10,802,182	3.71	
Apr-22	70.28	89.13	7,397,680	3.73	Apr-23	102.07	99.7	10,606,230	3.68	
May-22	55.81	78.10	6,360,710	3.91	May-23	95.10	100	10,178,230	3.67	
Jun-22					Jun-23					
SUM	57.34	83.18	71,148,121	3.95	SUM	88.15	95.87	102,956,180	3.71	

Increase/Decrease

34.95

13.23

-6.47

04/06/23

Sub-Divisional Engineer (Opn)

Haripur 412MW CCPP
A.H.M Anwar Islam
Sub-Divisional Engineer (Operation)
Haripur 412 MW CCPP, EGCB
Haripur, Bandar, Narayanganj.

04.06.2023

Executive Engineer (Opn)

Haripur 412MW CCPP
Md. Masud Alam
Executive Engineer (Operation)
Haripur 412 MW CCPP, EGCB
Haripur, Bandar, Narayanganj.

04.06.2023

Superintending Engineer (Opn)

Haripur 412MW CCPP
সৈয়দ গোলাম রুহা
তত্ত্বাবধায়ক প্রকৌশলী (পরিচালন)
হরিপুর ৪১২ মেঃ ওঃ সিসিপিপি, ইজিসিপি
বন্দর, নারায়ণগঞ্জ।